



Department of Public Safety
Daily Crime & Fire Safety Log

Wednesday January 5, 2011

| Nature <i>(Classification)</i> | Case Number | Date/Time Reported | Date/Time Occurred | General Location <i>(on/off campus)</i> | Disposition |
|--|--------------------|-------------------------------|-------------------------------|---|---|
| Alarm / Intrusion | 2011-0098 | January 5, 2011 @ 0538 hrs | January 5, 2011 @ 0538 hrs | Botany | Closed: Employee activated. |
| Property / Lost | 2011-104 | January 5, 2011 @ 1726 hrs | January 5, 2011 @ 1200 hrs | Gateways Vidinghoff | Closed: Property found. |
| Alarm / Fire | 2011-115 | January 5, 2011 @ 2212 hrs | January 5, 2011 @ 2212 hrs | Bertrand Library | Closed: Caused by burnt elevator motor. |