



Department of Public Safety
Daily Crime & Fire Safety Log

Sunday July 29, 2012

Nature (Classification)	Case Number	Date/Time Reported	Date/Time Occurred	General Location (on/off campus)	Disposition
Alarm / Fire	2012-7689	July 29, 2012 @ 0617 hrs	July 29, 2012 @ 0617 hrs	Smith Hall	Closed: Caused by dirty detector.
Alarm / Intrusion	2012-7690	July 29, 2012 @ 0628 hrs	July 29, 2012 @ 0617 hrs	Marts Hall	Closed: Caused by scheduled power outage.